

Medina Fire Department

Date: _____

300 West Reagan Parkway
Medina, Ohio 44256 - 1547
Office (330) 725-1772
Fax (330) 723-5806

Badge # : _____

Telephone #: _____

Inspector: _____

Address: _____

Occupant: _____

Building Owner: _____

Business Owner: _____

Electrical

- _____ (EL001) Exposed or broken outlet plates or switches, open junction box, painted outlets.
_____ (EL002) Exposed, bare or improper wiring.
_____ (EL009) Electrical panel clearance required (30 inches wide, 36 inches depth, 78 inches height).
_____ (EL004) Electrical panel and or electrical room not labeled. _____ (EL005) Open slot in electrical panel.
_____ (EL006) Improper use of extension cords.
_____ (EL007) Multi-plug adaptor being used.
_____ (EL008) _____

Exits

- _____ (EX001) Exit door blocked, locked, obstructed, or inoperable.
_____ (EX006) Exit signs not illuminated. _____
_____ (EX002) Exit signs backup lighting not working. _____
_____ (EX003) Emergency lighting not operational. _____
_____ (EX004) Improper locks on egress doors (slide bolts, hasps, padlocks, bars, other).
_____ (EX005) Self-closing door mechanism not operational.
_____ (EX007) _____

Fire Protection

- _____ (FP001) Fire extinguisher out of date (required annual service).
_____ (FP002) Fire extinguisher not mounted or obstructed.
_____ (FP011) Fire extinguisher needs recharged.
_____ (FP003) Hood system out of date (required 6 month service).
_____ (FP004) Obstructed sprinkler heads (required 18 inch minimum clearance).
_____ (FP005) Fire doors blocked, obstructed, not operational.
_____ (FP006) Lack of fire extinguishers, rating required 2A:10BC or larger.
_____ (FP014) 4A:20BC rated fire extinguisher within 20 feet of battery charging area.
_____ (FP008) Lack of Test Records for Sprinkler System. _____ (FP009) Lack of Test Records for Standpipe System.
_____ (FP010) Lack of Test Records for Fire Alarm System.
_____ (FP012) Lack of Test Records for annual fire door test (roll-up & sliding).
_____ (FP013) _____

Miscellaneous

- _____ (M001) Compressed gas cylinders unsecured. _____ (M008) Improper storage flammable liquids.
_____ (M002) Accumulation of waste. _____ (M009) Improper use flammable liquids.
_____ (M003) Storage too close to ceiling. _____ (M010) Ceiling tiles missing.
_____ (M004) Address must be posted on building. _____ (NVAT) No violations as this time.
_____ (M007) Improper storage of combustible materials.
_____ (M012) _____

Compliance date: _____

Date Re-inspection #1 Conducted _____

Badge # _____

Compliance date: _____

Date Re-inspection #2 Conducted _____

Badge # _____

Compliance date: _____

Date Re-inspection #3 Conducted _____

Badge # _____

Received by: _____

MFDINS6-Jun.08

White - Business Owner / Yellow - Reinspection / Pink - File